

University of New Hampshire  
Single Occupancy Public Restrooms  
(less than 125 square feet)

BLDG NAME	BLDG #	ROOM #/ FLOOR	ROOM USE	# OF FIXTURES	ACCESSIBILITY	SIGNAGE	COMMENTS
Dairy Bar		Main Floor T1	VMP	1	No	Men	2
		Main Floor T2	VWP	1	No	Women	2
Dimond Library	057	331	VWP	1	Yes	Women (universal)	4
		333	VMP	1	Yes	Men (standard)	4
		G02	VRP	1	Yes	Lavatory	4
Elliot Alumni Ctr.	154	109	VWP	1	Yes	Women	3
Equine Center	28	100	VMP	1	Yes	Male/Handicap symbols	5
		101	VWP	1	Yes	Female/Handicap symbols	5
Field House	032	226A	VMP	1	No	Men	0
Hamilton-Smith	008	121	VRP	1	No	None	0
		224	VRP	1	No	Room Number only	0
		B43	VRP	1	No	None	0
Health Services	097	205	VRP	1	No	Restroom w/Male/Female symbols	2
		211	VRP	1	Yes	Restroom w/Male/Female symbols	2
		232	VRP	1	Yes	Restroom w/Male/Female symbols	4
		247	VRP	1	Yes	Restroom w/Male/Female symbols	4
		248	VRP	1	Yes	Restroom w/Male/Female symbols	4
		A136	VRP	1	Yes	Restroom w/Male/Female symbols	3
		115	VRP	1	Yes	Restroom w/Male/Female symbols	4
Hewitt Annex	100	111	VWP	1	No	Women	2
Hood House	029	107	VRP	1	Yes	Toilet w/symbol	4
		203A	VRP	1	Yes	None	3
		210	VRP	1	Yes	Toilet	2
		B07AB	VRP	1	Yes	None	2
		B12A	VRP	1	Yes	None	3/2
Huddleston	018	205A	VRP	1	No	None	0
Kendall	110	101	VRP	1	Yes	Restroom - Male/Female/Handicap symbols	3
		102	VRP	1	Yes	Restroom w/Male/Female/Handicap/No Smoking symbols (paper)	4
Leavitt Lane - Human Resources		104	VRP	1	Yes	Restroom	5
		105	VRP	1	Yes	Restroom	5
Louella Pettee House	038	203W	VRP	1	No	None	0
		302W	VRP	1	No	None	0
MacFarlane Greenhouse	024	120	VWP	1	Yes	Women	2
		121	VMP	1	Yes	Men	2
McConnell	089	111	VRP	1	Yes	Handicapped	4
Memorial Union Building		146	VRP	1	No	Men/Women Symbol	2
		152	VRP	1	No	Men/Women Symbol	2
NEC Adams Tower	259	103A	VMP	1	Yes	Male/Handicap symbols	2
		104A	VWP	1	Yes	Female/Handicap symbols	2
		121	VWP	1	Yes	Women w/symbol	4
		122	VMP	1	Yes	Men w/symbol	4
NH Hall	007	202A	VRP	1	No	None	0
Parsons	082	128	VRP	1	Yes	None	3/2
		229	VRP	1	Yes	None	3/2
Paul Creative Arts	061	A211	VRP	1	Yes	Restroom - Male/Female/Handicap symbols (paper sign says "This is a unisex bathroom. If you would like complete privacy, the entry door can be locked.")	5
		M120	VRP	1	Yes	Restroom - Male/Female/Handicap symbols	5
		DB02A	VMP	1	No	None	2
Perpetuity		1st Fl - No room #	VMP	1	Yes	Men w/man and handicap symbols	5
		1st Fl - No room #	VWP	1	Yes	Woman w/woman and handicap symbols	5
Pettee Hall	035	210	VRP	1	Yes	Lavatory w/symbol	5
		234	VRP	1	Yes	Lavatory w/men-women symbols	5
		315	VRP	1	Yes	Lavatory w/symbol	5
Putnam Hall	049	117	VWP	1	Yes	Women	2

University of New Hampshire  
Single Occupancy Public Restrooms  
(less than 125 square feet)

BLDG NAME	BLDG #	ROOM #/ FLOOR	ROOM USE	# OF FIXTURES	ACCESSIBILITY	SIGNAGE	COMMENTS
Ritzman Lab	060	123	VRP	1	Yes	Restroom - Male/Female/Handicap symbols	5
Schofield (North)	39	306	VRP	1	No	None	2
		116	VRP	1	Yes	Men/Women/Handicapped symbol	5
		111	VRP	1	No	No signage except room #	2
		112	VWP	1	No	Women	2
		2nd Fl - No room #	VRP	1	No	None	2
Schofield (South)	39	G27	VMP	1	Yes	Men w/symbol	4
Stillings	070	G28	VWP	1	Yes	Women w/symbol	4
Stoke Hall	077	B29C	VMP	1	Yes	Men w/symbol	4
		B29E	VWP	1	Yes	Women w/symbol	4
Thompson Hall	001	206A	VRP	1	Yes	Restroom	4/3
		206B	VRP	1	Yes	Restroom	4/3
		G07	VRP	1	Yes	Restroom - Male/Female/Handicap symbols	4
Verrette	87	1st Fl - No room #	VRP	1	Yes	None	5
		202	VWP	1	No	Women	2
		3rd Fl - No room #	VRP	1	No	None	2
		203	VMP	1	No	Men	2
Visitor Information	033	103	VMP	1	Yes	Men	4
		104	VWP	1	Yes	Women	4
West Edge - Printing & Mailing Services		104	VMP	1	Yes	Men	5
		105	VWP	1	Yes	Women	5
Whittemore Center	337	112	VRP	1	Yes	None	5
Wolf House	073	104	VRP	1	Yes	Paper sign for Room 104	4
		205	VRP	1	No	Two-sided paper sign reading Occupied/Available	0
<b>TOTALS:</b>							
<i>Room Use</i>	<i>77</i>		<i>Accessibility</i>	<i>77</i>		<i>Comments Rating</i>	<i>77</i>
Women's Room	16		Yes	54		0	9
Men's Room	14		No	23		1	0
Gender Neutral	47					2	23
						3/2	3
						3	4
						4/3	2
						4	20
						5	16
<b>Room Use Code:</b>					<b>Comments Rating Key:</b>		
VWP	Women's Room			0	NA		
VMP	Men's Room			1	Safety Hazard		
VRP	Gender Neutral			2	Major Barrier(s): no approach, no entry (door isn't 32" w), no usability (not 5x5, sink height/clear)		
				3	Moderate: door pressure (5 lbs), door clear (inside pull, 15"-18"), door lever (fist), grab bars, toilet paper dispensers		
				4	Negligible: strobe, sink fixtures, protection of pipes, soap dispensers, paper towel dispenser		
				5	ADA compliance met		